

Annexure D

BUILDING SAFETY CERTIFICATE

No.

Dated: 01-05-2026

It is certified that the existing building St. BENEDICT'S ENGLISH MEDIUM HIGH SCHOOL (name of the building or premises) at R.S. NO. 143 (A), KOTHURU TADEPALLI (V), VIJAYAWADA RURAL (M), NTR DISTRICT (address) is having block(s)/Floor(s) as per details below:

Detail of Block(s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	G+2	—	—	—	—	—

The building is owned/occupied by St. BENEDICT'S ENGLISH MEDIUM HIGH SCHOOL (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of R.E.B. Dept. Govt. G.A.P. (Name of Department/ Govt.) on 01-05-2026 (date of inspection) in the presence of Fr. JOBIN JOSEPH, Correspondent, St. BENEDICT'S ENGLISH MEDIUM HIGH SCHOOL, KOTHURU TADEPALLI, VIJAYAWADA NTR DIST (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school with effect from 01-05-2026 for a period of TWO years in accordance with rule and subject to compliance of the specific conditions as appended.

- 1.
- 2.
- 3.
- 4.

Issued on 01-05-2026 at VIJAYAWADA by Y. SASHI BHUSHAN

* Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

Y. SASHI BHUSHAN
Deputy Executive Engineer (R&B),
Buildings Sub Division
Vijayawada.

Signature with Seal Y. SASHI BHUSHAN
Name: Y. SASHI BHUSHAN
Designation: DEF (R&B)

Name & Address of Department/ Office: _____

01. DEPUTY EXECUTIVE ENGINEER
ROADS AND BUILDINGS DEPARTMENT
BUILDINGS SUB DIVISION
VIJAYAWADA

68 | Page


Jayaraman
Manager

St. Benedicts (E.M) High School
Kothuru Tadepalli, Vijayawada Rural,
NTR (Dt). Andhra Pradesh


Principal
St. Benedicts (E.M) High School
Kothuru Tadepalli, Vijayawada Rural,
NTR (Dt). Andhra Pradesh

SOUNDNESS CERTIFICATE

1	Address of the School/ College	: St. Benedict's E.M. High School, Kothuru Tadepalli (V), Vijayawada Rural - 520012
2	College/ School Running in	: RCC Building G+2 Roof with RCC Slab and above terrace Roof with GI Sheet
3	No. of Floors	: G+2
4	Silt Floor/ground floor used as	: Office and Class Room
5	constructed in the year	: 2009 & south side building 2018
6	constructed As per approved plan	: Yes
7	present period up to which certificate is in force	: NA
8	Any cracks developed in the walls in superstructure and basement.	: Nil
9	Condition of lintels and walls above the lintel.	: Good
10	Condition of beams and the Trusses	: Good
11	Development of Cracks	: Nil
12	Exposed reinforcement if any	: Nil
13	Condition of Doors and Windows	: Good
14	The width of the staircase flight is	: 1.90 m
15	Tread width is	: 0.30m
16	The height of rise	: 0.15m
17	The height of railing	: 0.80m
18	The height of Corridor parapet wall	: NA
19	Doorway dimensions	: D: 1.00X2.10m
20	Height of Parapet wall	: 1.00m
21	Internal corridor width	: NA
22	Any Cantilever corridors	: 2.10m


Manager

St. Benedicts (E.M) High School
Kothuru Tadepalli, Vijayawada Rural,
NTR (Dt). Andhra Pradesh


Principal

St. Benedicts (E.M) High School
Kothuru Tadepalli, Vijayawada Rural,
NTR (Dt). Andhra Pradesh

23	Number of exits	: 3 No
24	There is high tension electricity lines passing near to the building	: No
25	There is Petrol/Gas stations near to the building	: No
26	Grills are provide for all sides of balconies as children safety point of view	: Yes
27	Building plan submitted	: Yes
28	Building Foundation and Structural design submitted	: No
29	Building was last painted in the year	: 2024
How ever for the building is safe for a period of two years i.e., from 01.05.2026 to 30.04.2028.		

June 15/2024
Deputy Executive Engineer, (R&B)
Buildings Sub Division, Vijayawada.

June 15/2024
Deputy Executive Engineer (R&B)
Buildings Sub Division
Vijayawada.

Jayaraju
Manager
St. Benedicts (E.M) High School
Kothuru Tadepalli, Vijayawada Rural,
NTR (Dt). Andhra Pradesh

Rajam
Principal
St. Benedicts (E.M) High School
Kothuru Tadepalli, Vijayawada Rural,
NTR (Dt). Andhra Pradesh