

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 22/7/2023

It is certified that an inspection team headed by Dr. K. Narendra Kumar & team
(Name of Officers with designation) from Primary Health centre, Velagaleru.
(Name of Department/ Office) inspected the St. Benedict's E.M. High School, K. Tadepalli
(Name & Address of the school) on 22/07/2023 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
The above is valid for a period of 1 year.

Signature with Seal: Kumar

Name

Designation : Dr. K. Narendra Kumar
MEDICAL OFFICER
PRIMARY HEALTH CENTRE
VELAGALERU-521 229
Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To
St. Benedict's E.M. High School
K. Tadepalli, Vijayawada Rural.

Primary Health centre
Velagaleru
521229.

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Jayanaray
Manager
St. Benedicts (E.M) High School
Kothuru Tadepalli, Vijayawada Rural,
NTR (Dt). Andhra Pradesh

[Signature]
Principal
St. Benedicts (E.M) High School
Kothuru Tadepalli, Vijayawada Rural,
NTR (Dt). Andhra Pradesh

SANITARY CERTIFICATE

This is to certify that the building situated at Kothuru Tadepalli, belonging to St. Benedict's E.M. Nursery, Primary & High School, Vijayawada Rural Mandal, Krishna District, was inspected and found to be maintained in a neat and hygienic condition. The sanitary facilities, including toilets, bathrooms, urinals, and the drainage system available in the institution, are adequate to meet the needs of the occupants. The premises, buildings, and drinking water facilities are being maintained properly in a hygienic manner.

rich
NR-20

Jayaraju
Manager

St. Benedicts (E.M) High School
Kothuru Tadepalli, Vijayawada Rural,
NTR (Dt). Andhra Pradesh

Cur
16/06/2024
MEDICAL OFFICER
PRIMARY HEALTH CENTRE
VELAGALERU-521229.

R. John
Principal

St. Benedicts (E.M) High School
Kothuru Tadepalli, Vijayawada Rural,
NTR (Dt). Andhra Pradesh

GOVERNMENT OF ANDHRA PRADESH
RURAL WATER SUPPLY AND SANITATION DEPARTMENT

Internal Water Quality Monitoring Laboratory
Opp:PWD Grounds, Bunder Road, Vijayawada - 520 002

Report of Physical, Chemical and Bacteriological Examination of Drinking Water

Sample Referred from : St. Benedict's (E.M) High School
Collection Date : 29.04.2026
Village : Kothuru Tadepalli
Mandal : Vijayawada Rural
Source : R O Water


<u>A.Physical</u>	<u>Result</u>	<u>Desirable Limit (as per IS 14543:2004)</u>
1.Turbidity(In NTU)	: Nil	2
2.pH	: 6.86	6.5 - 8.5
3.Electrical Conductivity (Micromhos/Cm)	: 212	

<u>B.Chemical</u>	<u>The Following Results are in Milligram per Litre</u>	
4.Total Dissolved Solids	: 127	500
5.Alkalinity (As CaCO_3) (Phenolphthaleine+Methyle Orange)	: 44	200
6.Total Hardness(As CaCO_3)	: 40	300
7.Calcium (As CaCO_3)	: 6	75
8.Nitrate (As NO_3)	: Nil	45
9.Sulphate (As SO_4)	: 8	200
10.Chloride (As Cl)	: 35	200
11.Fluoride (As F)	: 0.16	1.0
12.Iron (As Fe)	: 0.01	0.1
13.Magnesium (As Mg)	: 6	30


MICROBIOLOGICAL PARAMETERS

1. MPN of Coliform	: Nil
2. Escherichia Coli	: Absent

Remark: The above source of water is Chemically and Bacteriologically satisfactory in all aspects and fit for Human Consumption.


Manager

St. Benedicts (E.M) High School
Kothuru Tadepalli, Vijayawada Rural,
NTR (Dt). Andhra Pradesh


Chemist/Microbiologist
Panchayat Water Quality Monitoring Laboratory
Vijayawada
Vijayawada


Principal
St. Benedicts (E.M) High School
Kothuru Tadepalli, Vijayawada Rural,
NTR (Dt). Andhra Pradesh